

**An Infection Control Permit is required for Class III or Class IV construction projects.
Display permit at entrance to work area during entire construction period.**

Facility: St. John Hospital & Medical Center	ICRA Assessment Date:
Project Name	Project Number:
Phase:	Project Start Date:
Location of Construction	Estimated Duration:
Project Manager	-Telephone:
	Mobile/Pager:
Contractor:	Telephone:
	Mobile/Pager:
Unit Supervisor/Coordinator	Telephone:
	Mobile/Pager:
Infection Control Practitioner	Telephone:
Infection Control Precautions	Pager/Mobile:

Class III

1. Obtain Infection Control Permit before construction begins
2. Remove or isolate HVAC system in area where work is being done to prevent contamination of duct system. Block supply vents and filter return ducts.
3. Complete all critical barriers, i.e. sheetrock, plastic, to seal area from non-work area
4. Document and maintain negative air pressure within work site utilizing HEPA-equipped air filtration units.
5. Contain construction waste before transport in tightly covered containers.
6. Do not remove barriers from work area until completed project is thoroughly cleaned by Environmental Services.
7. Remove barrier materials carefully to minimize spreading of dirt and debris associated with construction.
8. Vacuum work area with HEPA-filtered vacuums.
9. Wet mop with disinfectant.
10. Remove isolation of HVAC system in areas where work is being performed.

Class IV

1. Obtain Infection Control Permit before construction begins.
2. Remove or isolate HVAC system in area where work is being done to prevent contamination of duct system. Block supply vents and filter return ducts.
3. Complete all critical barriers, i.e. sheetrock, plastic, to seal area from non-work area.
4. Document and maintain negative air pressure within worksite using HEPA-equipped air filtration units.
5. Seal holes, pipes, conduits, and punctures appropriately.
6. Construct anteroom and require all personnel to pass through this room so they can be vacuumed using a HEPA vacuum cleaner before leaving the worksite or they can wear cloth or paper coveralls that are removed each time they leave the worksite.
7. Personnel entering worksite are recommended to wear shoe covers. Shoe covers must be removed each time the worker exits the area.
8. Contain construction waste before transport in tightly covered containers.
9. Do not remove barriers from work area until completed project is thoroughly cleaned by Environmental Services.
10. Remove barriers carefully to minimize spreading of dirt and debris associated with construction.
11. Vacuum work area with HEPA filtered vacuums.
12. Wet mop area with disinfectant.
13. Remove isolation of HVAC system in areas where work is being performed.

Additional requirements: _____

